

From: (b)(6) Mr CIV USAF USCENTCOM CCHC/F  
Sent: Friday, February 04, 2011 2:13 PM  
To: (b)(6) CTR USCENTCOM CCHC-F; ' (b)(6) SAM'  
Cc: (b)(6) CDR MIL USN USCENTCOM CCJ4-E; (b)(6) Mr CIV USN'  
Subject: RE: window backwards?

Seems to me a saw a news article with the same problem . . .

From: (b)(6) CTR USCENTCOM CCHC/F  
Sent: Friday, February 04, 2011 12:54 PM  
To: (b)(6) SAM'  
Cc: (b)(6) CDR MIL USN USCENTCOM CCJ4/E; (b)(6) Mr CIV USN'; (b)(6) Mr CIV USAF USCENTCOM CCHC/F  
Subject: window backwards?

I might be wrong, but it appears that the glass for the service window going into DI-2 is installed backwards. I can see in from the hallway into DI-2 just fine, but can't see out from DI-2 very well. The idea is to keep people from the hallway from seeing into DI-2. Can you have somebody check it out?

Regards,  
(b)(6)

(b)(6), R.A., CTR  
CCHC MILCON Manager

(b)(6)