

From: (b)(6) [CDR MIL USN USCENTCOM CCJ4/E](#)
To: (b)(6) [MIL USA USCENTCOM CCJ4/E](#)
Cc: (b)(6) [Mr. CIV USAF USCENTCOM CCJ4/E](#); (b)(6) [LTC MIL USA USCENTCOM CCJ4/E](#)
Subject: CENTCOM HQ Weekly Status Report
Date: Friday, January 21, 2011 1:07:09 PM
Attachments: Weekly 21 Jan 11.docx

Col (b)(6) -

Weekly status report enclosed. A Leak was discovered in the Uninterruptible Power Supply (UPS) room yesterday evening from an Air Conditioning unit resulting in ~\$450k of damage to the UPS system. Coastal Mechanical's insurance is expected to cover the loss, and the damaged equipment is expected to be replaced by April. More schedule data is expected next week, and J6 MILCON has been asked to assess schedule impact.

V/r

(b)(6)

(b)(6)
CDR, USN
CCJ4/E - CENTCOM HQ Construction Manager

(b)(6)

((b)(6)